



Sri Lanka CERT (Pvt.) Ltd

ADDENDUM NO 01 - TO THE BIDDING DOCUMENT

FOR THE

Procurement of Production Data Center Co-Location for NCA

INVITATION FOR BIDS No: CERT/GOSL/SER/NCB/2025/23

August 2025

ADDENDUM NO 01 - TO THE BIDDING DOCUMENT

INVITATION FOR BIDS No: CERT/GOSL/SER/NCB/2025/23

This Addendum to the Bidding Document of above procurement incorporates following amendments. All bidders shall comply with these amendments in addition to the clarifications issued.

Amendments

Sr.No.	RFP Reference	RFP Clause	Query	SL Cert Response
1	Section II. Bidding Data Sheet → B. Content of Bidding Document →10.1 Pg. No:24	If further clarifications are required, such quarries shall be received by the employer on or before August 26, 2025. Any quarries received by the employer after this date will not be entertained and clarified.	Please confirm whether the final date for submitting clarifications can be extended to September 4 th , 2025.	Sri Lanka CERT has agreed to extend the clarification submitting deadline, and the last date for submitting clarifications will be on or before 4th September 2025.
2	Section II. Bidding Data Sheet → 5.3 (a) Pg. No: 23	In addition to Power of Attorney, any other valid proof for authorizing the signatory of the Bid to commit the Bidder, such as Board Resolution, Articles of Association and court decisions, etc. are acceptable.	Is it required to provide a Power of Attorney and/or any other valid proof	Sri Lanka CERT agreed to change it as follows “In addition to Power of Attorney, or any other valid proof for authorizing the signatory of the Bid to commit the Bidder, such as Board Resolution, Articles of Association and court decisions, etc. are acceptable.”
3	7. Security monitor → 7.3 Security monitoring for Server cage dedicated to Sri Lanka CERT (Video Surveillance)		What is the required number of CCTVs and their locations?	Sri Lanka CERT requires a minimum of 2 CCTVs, which should cover the cage door entrance as indicated in the diagram attached as Annexure 1.
4	1 Data Center Standards → 1.2 Uptime Guarantee	~99.8% uptime	Please check the possibility of changing the “~99.8% uptime to “99.74% uptime”.	Sri Lanka CERT has agreed to revise the requirement from “~99.8% uptime” to “99.74% uptime”.

5	2. Specifications of the building, Server room and data storage room 2.4 Physical barriers	Physical barriers need to be placed (e.g., solid walls that extend from real floor to real' ceiling) to prevent unauthorized entry and environmental contamination	Is it mandatory to provide physical barriers within the solid wall?	The bidder shall comply with the RFP requirements provided by Sri Lanka CERT.
6	4 Electricity Supply and Relevant Equipment → 4.8 Ability to provide 240 V 2*16A /2*32A/2*64 Pg. No:40	(active/active by independent distribution paths, load balanced), and each rack should be capable of supplying up to 240 V 2*16A /2*32A/2*64	Could you please clarify whether the actual requirement is 16A or 32A?	Sri Lanka CERT has agreed to proceed with 32A.
7	10 Internet Connectivity → Penalties Pg. No:44		What are the cable management requirements?	Sri Lanka CERT requires CAT6 Ethernet cabling
8	Service Level Agreement (SLA) and Penalty Schema	In case of interruptions, penalties will be calculated as per the formula given below (per hour basis):	Please allocate the maximum cap we request that it be set at 10% as the maximum.	Sri Lanka CERT has agreed to provide a maximum cap of 10%.
9	13 Compliance & Audit → 13.3 Physical security audits	Annual third-party physical security audits. The 2024 audit report must be submitted with the RFP. Failure to provide this report will result in Sri Lanka CERT deeming the bidder non-compliant with this requirement.	This is covered under the ISO audit, and due to its criticality and confidentiality, we are not in a position to provide the report to any third party, as the data center also serves other customers. Therefore, we request that this section be removed.	Sri Lanka CERT has agreed to remove Section 13.3 from the RFP.

Note 1.

The price schedule has been revised to the following format, and all bidders are required to submit their proposals using the updated price schedule.

Price Schedule Pg. Number 33

1	2	3	4	5	6	7	8	9
Item No	Description of Goods	unit	Unit price Excluding VAT LKR	Number of Months	Total Price Excluding VAT LKR	Discounted Total Price (If any) Excluding VAT LKR	VAT	Total Price Including VAT LKR
			<i>[insert price per unit]</i>		<i>[Col (3)*(4)*(5)]</i>	<i>[insert total cost for total quantity for inland transportation and other services required]</i>	<i>[insert total VAT for total quantity]</i>	
01	One time cost for cage preparation	01		N/A				
02	Monthly cost for space for 42U rack and requirements (Excluding power consumption)	02		36				
03	Monthly Cost for power consumption per kWh. (For both racks)	800		36				
Total								

* Payments will be arranged on a monthly basis and will cover only Items 02 and 03. Item 01 represents a one-time cost and will be released upon project completion, in accordance with the timeline provided in the RFP submitted by Sri Lanka CERT.

Note 2.

Please note that, considering the criticality of this project and the timeline, the Procurement Committee has decided **not to grant** a time extension. Accordingly, as per the RFP, the proposal submission will be closed as originally scheduled.

Annexure 1

CCTV Location

